

EML AIR PTY LTD ABN 98 006 878 342 **Melbourne (Head Office)** PO Box 466, Canterbury, Victoria 3126 427 Canterbury Road, Surrey Hills, Victoria 3127 **T.** +61 3 9836 1999 **F.** +61 3 9830 0670 **E.** emlair@emlair.com.au **W.** www.emlair.com.au

Our reference: Page 1 of 4

N90509

5 March 2013

Terminals Pty Ltd PO Box 148 MATRAVILLE NSW 2036

Attention Mr Geoff Millard

PORT BOTANY PLANT

Emission Testing Report - FEBRUARY 2013

Tests were performed at the request of Terminals Pty Ltd to determine emissions to air as detailed below;

Test Summary						
Location	Test Date	Test Parameters*				
EPA 7 – Bitumen Combuster	6 February 2013	Volatile organic compounds (VOC's), hydrogen sulfide, nitrogen oxides, carbon dioxide, oxygen				

* Flow rate, velocity, temperature and moisture were determined unless otherwise stated.

Please refer to the following pages for results, plant operating conditions, test methods, quality assurance / quality control information and definitions.

Heath Thatcher DipAppSc Client Manager ad doc:n90509 Melissa Reddan BAppSc Compliance Manager



This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO/IEC 17025. This document shall not be reproduced except in full

Air Emission Specialists Melbourne • Sydney • Perth• Brisbane

EML AIR PTY LTD ABN 98 006 878 342

Test report prepared for Terminals Pty Ltd

Our reference: N90509 Page 2 of 4 5 March 2013

RESULTS

Date 6/02/2013 Report N90509 Licence No. - EML Staff SW		Client Stack ID Location	Terminals Pty I EPA 7 Bitumer Port Botany	_td Combustor		State		NSW	
Process Conditions Reason for testing:	Client requested testing to d	s. letermine emiss	ions to air						
Sampling Plane Details									
Sampling plane dimensions (mm Sampling port size, number & de Access & height of ports Duct orientation & shape Downstream disturbance Upstream disturbance No. traverses & points sampled Traverse method & compliance	1) & area spth			4" F Change	980 Flange (x2) Fixed ladder Vertical Exit in diameter 2 AS4323.1	0.754 m ² 20 m Circular 6 D 8 D 12 Ideal			
Comments All results reported on a dry basis at NTP									
Stack Parameters Moisture content, %v/v Gas molecular weight, g/g mole Gas density at NTP, kg/m ³ % Oxygen correction & Factor		8.8 28.4 (wet) 1.27 (wet) 3 %			29.4 (dry) 1.31 (dry) 2.59				
Gas Flow Parameters Temperature, K Velocity at sampling plane, m/s Volumetric flow rate, discharge, Volumetric flow rate (wet NTP), n Volumetric flow rate (dry NTP), n Mass flow rate (wet basis), kg/ho Velocity difference, %	m³/s n³/s sur	1108 9.5 7.1 1.8 1.6 8000 -1							
Hydrogen Sulfide Sampling time Hydrogen sulfide			Concentration mg/m³ 0.014	Results 1215-1315 O2 corrected mg/m ³ 0.036	Mass Rate mg/s 0.023				
Gases Sampling time	Average 1212-1311 Concentration O2 corrected	Mass Rate	Concentration	Minimum 1212-1311 O2 corrected	Mass Rate	Concentration	Maximum 1212-1311 O2 corrected	Mass Rate	100 Percentile Concentration limi
Nitric oxide (as NO ₂) Nitrogen dioxide (as NO ₂) Nitrogen oxides (as NO ₂)	mg/m³ mg/m³ 73 190 <4.1	mg/s 120 <6.6 120	mg/m³ 70 <4.1 70 Concentration	^{mg/m³} 180 <11 180	mg/s 110 <6.6 110	mg/m ³ 76 <4.1 76 Concentration	^{mg/m³} 200 <11 200	mg/s 120 <6.6 120	^{mg/m³} 350
Carbon dioxide Oxygen	% 4.4 14		% 4.2 13.8			% 4.6 14.4			
VOC's (as n-Propane) Sampling time			Concertation	Results 1215-1315	Maga Data				Licence Limit
Total			mg/m ³	mg/m ³	mg/s				mg/m³ 40
VOC's (speciated) Sampling time Detection limit ⁽¹⁾			Concentration mg/m ³ <0.18	Results 1215-1315 O2 corrected mg/m ³ <0.48	Mass Rate mg/s <0.3				

(1) Unless otherwise reported, the following target compounds were found to be below detection: Ethanol, Isopropanol, Isobutanol, Butanol, 1-Methosy-2-propanol, Cyclohexanol, 2-Butoxyethanol Pertane, Hexane, Heptane, Octane, Norane, Decane, Undecane, Dodecane, Tridecane, Cyclohexane, 2-Abethylnexane, 2-Abethylnexane, assume isocatane, Methylcyclohexane, alpha-Pinene, beta-Pinene, d-Limonene, 3-Carene Acetone, Methyl ethyl ketone, Ethyl acetate, Isopropyl acetate, MIBK, 2-Hexanone, Butyl acetate, 1-Methoxy-2-propyl acetate, Cyclohexanone, Cellosolve acetate, 2-Butoxyethyl acetate, Ethyldiglycol acetate, Diacetone alcohol, Isophorone Benzene, Tollene, Ethylbenzene, m-p-Xylene, Styrene, o-Xylene, Isopropylbenzene, Propylbenzene, 1,3,5-Trimethylbenzene, alpha-Methylstyrene, tert-Butylbenzene, 1,2,4-Trimethylbenzene, 1,2,3-Trimethylbenzene, n-Diethylbenzene

Benzene, Toubert, Europette, euro

NATA This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO/IEC 17025. This document shall not be reproduced except in full

> Air Emission Specialists MELBOURNE • SYDNEY • PERTH• BRISBANE

EML AIR PTY LTD ABN 98 006 878 342

Test report prepared for Terminals Pty Ltd

Our reference: N90509 Page 3 of 4 5 March 2013

PLANT OPERATING CONDITIONS

Unless otherwise stated, the plant operating conditions were normal at the time of testing. See Terminals Pty Ltd's records for complete process conditions.

Testing was performed during bitumen ship discharge operations to provide peak load rate between 1212 and 1315 on Wednesday, 6th February.

TEST METHODS

Unless otherwise stated, the following methods meet the requirements of the NSW Office of Environment and Heritage (as specified in the Approved Methods *for the Sampling and Analysis of Air Pollutants in New South Wales, January 2007*). All sampling and analysis was performed by EML Air unless otherwise specified. Specific details of the methods are available upon request.

Parameter	NSW Test	Reference	Uncertainty*	NATA Accredited	
	Method	Method		Sampling	Analysis
Sample Plane Criteria	TM-1	AS 4323.1	-	\checkmark	NA
Flow rate, temperature and velocity	TM-2	USEPA 2	8%, 2%, 7%	\checkmark	NA
Moisture content	TM-22	USEPA 4	8%	\checkmark	\checkmark
Hydrogen sulfide	TM-5	USEPA 11	not specified	\checkmark	\checkmark
Nitrogen oxides (NO _x)	TM-11	USEPA 7E	12%	\checkmark	\checkmark
Carbon dioxide	TM-24	USEPA 3A	13%	\checkmark	\checkmark
Oxygen	TM-25	USEPA 3A	13%	\checkmark	\checkmark
Volatile organic compounds	TM-34	USEPA 18	19%	\checkmark	\checkmark

* Uncertainty values cited in this table are calculated at the 95% confidence level (coverage factor = 2)

AS – Australian Standard USEPA – United States Environmental Protection Agency

TM - Test Method

QUALITY ASSURANCE / QUALITY CONTROL INFORMATION

EML Air Pty Ltd is accredited by the National Association of Testing Authorities (NATA) for the sampling and analysis of air pollutants from industrial sources (Accreditation number 2732). Unless otherwise stated test methods used are accredited with the National Association of Testing Authorities. For full details, search for EML Air at NATA's website www.nata.asn.au.

EML Air is accredited to Australian Standard 17025 – General Requirements for the Competence of Testing and Calibration Laboratories. Australian Standard 17025 requires that a laboratory have a quality system similar to ISO 9002. More importantly it also requires that a laboratory have adequate equipment to perform the testing, as well as laboratory personnel with the competence to perform the testing. This quality assurance system is administered and maintained by the Quality Assurance Manager.

A formal Quality Control program is in place at EML Air to monitor analyses performed in the laboratory and sampling conducted in the field. The program is designed to check where appropriate; the sampling reproducibility, analytical method, accuracy, precision and the performance of the analyst. The Laboratory Manager is responsible for the administration and maintenance of this program.



This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO/IEC 17025. This document shall not be reproduced except in full

Air Emission Specialists Melbourne • Sydney • Perth• Brisbane Test report prepared for Terminals Pty Ltd

Our reference: N90509 Page 4 of 4 5 March 2013

DEFINITIONS

The following symbols and abbreviations may be used in this test report:

- NTP Normal temperature and pressure. Gas volumes and concentrations are expressed on a dry basis at 0°C, at discharge oxygen concentration and an absolute pressure of 101.325 kPa, unless otherwise specified.
- Disturbance A flow obstruction or instability in the direction of the flow which may impede accurate flow determination. This includes centrifugal fans, axial fans, partially closed or closed dampers, louvres, bends, connections, junctions, direction changes or changes in pipe diameter.
- VOC Any chemical compound based on carbon with a vapour pressure of at least 0.010 kPa at 25°C or having a corresponding volatility under the particular conditions of use. These compounds may contain oxygen, nitrogen and other elements, but specifically excluded are carbon monoxide, carbon dioxide, carbonic acid, metallic carbides and carbonate salts.
- BSP British standard pipe
- NA Not applicable
- D Duct diameter or equivalent duct diameter for rectangular ducts
- < Less than
- > Greater than
- ≥ Greater than or equal to
- ~ Approximately



Air Emission Specialists Melbourne • Sydney • Perth• Brisbane