

EPA Licence #1048						
Sampling Point 11						
Pollutant	Biological Oxygen Demand	pH	Total Suspended Solids	Oil and Grease	Publishing date	Notes
Licence Limit	20	6.5 - 8.5	30	10		
Unit of Measure	g/l	pH unit	g/l	g/l		
Monitoring frequency	One sample per discharge event (maximum of 2 per month)					
Jan-18	No discharge					
Feb-18	No discharge					
Mar-18	No discharge					
Apr-18	No discharge					
May-18	No discharge					
29-Jun-18	<2	6.94	8	<5	13/07/2018	
Jul-18	No discharge					
29-Aug-18	<5	7.2	10	<5	5/09/2018	
Sep-18	No discharge					
Oct-18	No discharge					
Nov-18	No discharge					
16-Dec-18	<5	6.95	9	<4		
Jan-19	No discharge					
Feb-19	No discharge					
21-Mar-19	<5	6.8	<5	<5	1/04/2019	
Apr-19	No discharge					
May-19	No discharge					
Jun-19	<5	7	<5	<5	26/06/2019	
Jul-19	No discharge					
Aug-19	No discharge					
Sep-19	No discharge					
Oct-19	No discharge					
Nov-19	No discharge					
Dec-19	No discharge					
Jan-20	No discharge					
Feb-20	No discharge					