terminals pty. ltd.

EPA Licence #1048

Sampling Point 11..

Pollutant	Biological Oxygen Demand	pH	Total Suspended Solids	Oil and Grease	Publishing date	Totaliser Start / Finish
Licence Limit	**20**	**6.5 - 8.5**	**30**	**10**		**Values (L)**
Unit of Measure	**g/l**	**pH unit**	**g/l**	**g/l**		
Monitoring frequency	**One sample per discharge event (maximum of 2 per month)**					
Jan-18	No discharge					
Feb-18	No discharge					
Mar-18	No discharge					
Apr-18	No discharge					
May-18	No discharge					
29-Jun-18	<2	6.94	8	<5	13/07/2018	167860 / 318631
Jul-18	No discharge					
29-Aug-18	<5	7.2	10	<5	5/09/2018	318631 / 376589
Sep-18	No discharge					
Oct-18	No discharge					
Nov-18	No discharge					
16-Dec-18	<5	6.95	9	<4	20/12/2018	376589 / 741636
Jan-19	No discharge					
Feb-19	No discharge					
21-Mar-19	<5	6.8	<5	<5	1/04/2019	741636 / 1226757
Apr-19	No discharge					
May-19	No discharge					
Jun-19	<5	7	<5	<5	26/06/2019	1226757 / 1338453
Jul-19	No discharge					
Aug-19	No discharge					
Sep-19	No discharge					
Oct-19	No discharge					
Nov-19	No discharge					
Dec-19	No discharge					
Jan-20	No discharge					
09-Feb-20	<5	7.2	6	<5	15/02/2020	1338453 / 1417199
Mar-20	No Discharge					
Apr-20	No discharge					
26-May-20	<5	7.3	<5	<5		1417199 / 1623831
Jun-20	No Discharge					
17/07/2020	<5	7.6	5	<5		1623831 / 1806401
28/07/2020	<5	7.8	<5	<5		1806401 / 2812724
Aug-20	No Discharge					
Sep-20	No Discharge					
Oct-20	No Discharge					
3/11/2020	<5	7.4	6	<5		2812724 / 2952108
Dec 20	No Discharge					(Totaliser screen replaced)
Jan 21	No Discharge					
Feb 21	No Discharge					
23/03/2021	<5	6.9	10	<5		129 / 988180
18/08/2021	<5	7.7	6	<5		988180 / 1000775
25/08/2021	<5	7.8	<5	<5		1000775 / 1364451
Sept 2021	No discharge					
Oct 2021	No discharge					
Nov 2021	No discharge					
Dec-21	<5	7	<5	9		1364451 / 1558683
Jan-22	No discharge					
Feb-22	<5	6.9	<5	<5		1558683 / (continuing)
Mar-22	<5	6.9	<5	<5		/ 8682470
Apr-22						